A-007

Pass

Test Time	: 5/4/2021 3:53:12 PM	**Limit**	: TIA-568.3-D MultiMode REF Grade
Project	: Default	**Model**	: TestPro CV100
Profile	: MM Fiber	**Serial Number**	: Main: 5200-1227, Remote: 5200-1228
Operator	: Default	**Device Software**	: Main: 3.5.B5, Remote: 3.5.B5
Jumper Method	: One Jumper	**Calibration Date**	: Main: 1/13/2021, Remote: 1/14/2021
Main Adapter	: PROBE FIBER MM, S/N: 1044	**Remote Adapter**	: PROBE FIBER MM
Cable Type	: Generic MMF	**Cable Manufacturer**	: Generic
Connector	: LC	**Connector Manufacturer**	: Generic
Configuration	: Dual Ended Single Direction		
Length(m)	: 31.90	**Delay(ns)**	: 159.3
No. End Connectors	: 2	**End Connector Loss**	: 0.5
No. Connectors	: 0	**Connector Loss**	: 0.75
No. Splices	: 0	**Splice Loss**	: 0.3
Fiber Power Cable	: 56.39 V	**Performance Grade**	: OM4

850 nm

Pair	Result	Loss	Limit	Margin
Fiber 1 Main to Remote	Pass	-0.48	1.10	1.58
Fiber 2 Remote to Main	Pass	0.33	1.10	0.76

Unit	Reference Power
Main	-19.65
Remote	-19.21

1300 nm

Pair	Result	Loss	Limit	Margin
Fiber 1 Main to Remote	Pass	0.40	1.05	0.65
Fiber 2 Remote to Main	Pass	0.00	1.05	1.05

Unit	Reference Power
Main	-20.40
Remote	-20.37

Compliant Network

1 Gbit/s FC
1000BASE-SX
100GBASE-SR10
10BASE-FLand FB
10GBASE-LX4
10GBASE-SR/SW
2 Gbit/s FC
4 and 16 Mbit/s Token Ring
40GBASE-SR4
ATM at 155 Mbit/s
ATM at 622 Mbit/s
FDDI PMD
FOIRL
1000BASE-LX
100BASE-FX
100GBASE-SR4
10GBASE-LRM
10GBASE-SR
16 Gbit/s FC
32 Gbit/s FC
4 Gbit/s FC
8 Gbit/s FC
ATM at 52 Mbit/s
ControlNET
Fibre Channel (FC-PH) at 1062Mbit/s